

OPTIMAL SHUNT COMPENSATORS AT NONSINUSOIDAL BUSBARS

ELAMIN, IM; DUFFUAA, SO; BAWAH, AU

IEEE-INST ELECTRICAL ELECTRONICS ENGINEERS INC, IEEE TRANSACTIONS
ON POWER SYSTEMS; pp: 716-723; Vol: 10

King Fahd University of Petroleum & Minerals

<http://www.kfupm.edu.sa>

Summary

A model for determining an optimal shunt capacitor value at nonsinusoidal busbars combining three basic criteria maximizing the power factor, minimizing the line losses, and maximizing the transmission efficiency is developed. The choice of the capacitor value is constrained by the values that may cause resonance. This model was solved employing the penalty function approach and the golden Section Search algorithm for solving the linear load case. Furthermore nonlinear loads operating under nonsinusoidal conditions were investigated. The model for the nonlinear load is a two variable problem in L (inductor) and C (capacitor). The Direct Search Polytope algorithm is used. The solution of this model yields an optimal shunt LC compensator for the nonlinear load. However, since there are limitations on the practical values of shunt capacitor, a discretizing approach making use of standard shunt capacitor values is employed to guarantee a solution that can be implemented.

References:

1. 1980, IEEE STANDARD SHUNT
2. BAGHZOUZ Y, 1990, IEEE T POWER DELIVER, V5, P650
3. BAGHZOUZ Y, 1990, IEEE T POWER DELIVER, V5, P959
4. BAGHZOUZ Y, 1991, IEEE T POWER DELIVER, V6, P245
5. ERTEM S, 1990, IND COMMERCIAL POWER
6. GILL G, 1986, IEEE T INSTRUMENTATI, V35
7. GRAINGER JJ, 1981, IEEE T POWER APPARAT, V100, P1105
8. HEYDT GT, 1991, ELECTRICAL POWER QUA
9. MOKHTAR SB, 1979, NONLINEAR PROGRAMMIN
10. RAONIC D, 1988, EEE PES, P1

11. RICHARDS GG, 1986, IEEE T INSTRUM MEAS, V35, P365
12. RICHARDS GG, 1988, WINT IEEE P PES M
13. RONNIE CF, 1985, IEEE T POWER APPARAT, V104
14. SPHEPHERD W, 1979, ENERGY FLOW POWER FA
15. WILLEMS JL, IN PRESS ELECTRIC MA

For pre-prints please write to: abstracts@kfupm.edu.sa